


**NOTES:**

1. THE IRRIGATION SYSTEM SHALL BE CONNECTED DOWNSTREAM OF THE DOMESTIC SERVICE BACKFLOW PREVENTION ASSEMBLY -OR- SHALL HAVE ITS OWN METER AND BACKFLOW DEVICE.
2. THE WATER DEPARTMENT SHALL INSTALL METERS 2" AND SMALLER.

C:\04\0682\100 General Services\CAD\X-1.dwg Oct/31/05



DATE:	BY:	REVISION

**COMMERCIAL/INDUSTRIAL  
TYPICAL SERVICE LAYOUT**

SCALE:	N.T.S
APPVD:	BAB
DATE:	10/05
DWG NO.:	326