


MATERIALS:

1. MUELLER CORPORATION STOP NO. H-15008 OR APPROVED EQUAL. SET AT 45° ANGLE.
2. 1" SOFT TEMPER TYPE 'K' COPPER TUBING COMPLYING W/ASTM B-88.
3. MUELLER 3/4" X 3/4" X 1" "BULLHEAD" TEE NO. H-15381 OR APPROVED EQUAL.
4. 3/4" SOFT TEMPER TYPE 'K' COPPER TUBING COMPLYING W/ASTM B-88.
5. MUELLER ANGLE METER STOP NO. B-24258 OR APPROVED EQUAL.
6. BROOKS CONCRETE METER BOX, BODY NO. 37 OR APPROVED EQUAL.

NOTES:

1. SUBSTITUTES FOR ANY MATERIALS SHOWN SHALL BE APPROVED BY THE CITY ENGINEER.
2. ALL PIPE AND STRUCTURE ZONES SHALL BE BACKFILLED USING 3/4" MINUS CRUSHED AGG. AND COMPACTED TO 95% MAX. DENSITY DETERMINED BY AASHTO T-180.
3. SET CENTERLINE METER NUT OF ANGLE METER STOP 10" BELOW TOP CURB.
4. SEE STANDARD DRAWING FOR STD. 3/4" & 1" WATER SERVICE ADDITIONAL DETAILS.
5. METER BOX SHALL BE CENTERED OVER THE COMPLETED METER ASSEMBLY.

C:\04\0682\100 General Services\CAD\X-1.dwg Oct/31/05



DATE:	BY:	REVISION

STANDARD 1" DOUBLE SERVICE

SCALE:	N.T.S
APPVD:	BAB
DATE:	10/05
DWG NO.:	314