



**NOTES:**

1. FOR 12" AND SMALLER WATER MAINS
2. VENT PIPING TO BE GALVANIZED.
3. SLOPE COPPER TUBING FROM MAIN UP TO AIR VALVE 1% MIN.
4. SEE WATER SYSTEM STANDARDS FOR CORPORATION STOPS, FLARE OR COMPRESSION AS SPECIFIED.

D:\0582\100 General Services\CAD\X-1.dwg Oct/31/05



DATE:	BY:	REVISION

**1" AIR & VACUUM VALVE**

SCALE:	N.T.S
APPVD:	BAB
DATE:	10/05
DWG NO.:	317