



PIPE SIZE	NO. OF PIPE RESTRAINED
8"	3 (54')
12"	4 (72')
16"	5 (90')

NOTES:

- BACKFILL WILL BE COMPACTED 90% $\frac{3}{4}$ " GRAVEL, WITH MINIMUM 36" COVER.
- PROVIDE 24" SQUARE BY 4" THICK CONCRETE AROUND VALVE BOX OUTSIDE PAVED AREAS.

G:\PDX_Projects\04_0682\100_Planning\CAD\NP_Std_Details\X-1.dwg Jul/5/16



DATE:	BY:	REVISION

**STANDARD BLOWOFF
NEW CONSTRUCTION**

SCALE:	N.T.S
APPVD:	BAB
DATE:	07/16
DWG NO.:	309